

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Acapulco's Permit No. 112613	6/24/13  5/7/15	5/27/15	10/1/13  6/13/15 ?  7/10/15	11/06/13	To UC on 12-4-13	10-25-13 Passed  7/09/15 Failed 61% Full  7/10/15	In Compliance 5-7-15 NOV Letter Sent 78% Full Interceptors. No Response 5-31-15. 6-1-15 Chris sending NOV with Fine.  7-10-15: In Compliance  Passed
American Legion Permit No. 062415	1/6/15  5/07/15	2/6/15  5/27/15			Approved by Council on 7-8-15	12-18-14: Failed	Must apply for a FOG Permit NOV needs to be sent.  Per 4-28-15 internal mtg: Susan will send first NOV. 6-1-15: Received request for interceptor waiver.  Interceptor waiver granted 6-10-15. Permit was approved by Council on 7-8-15.  There is a 180 day compliance schedule in the permit. Compliance is required by January 7, 2016.  1-22-16: LKey spoke to Jerry Blake via telephone. Mr. Blake was informed what was needed to comply: * Submit vendor detail sheets for grease trap (GT) approval. * Replace existing 22 gpm GT with a new 50 gpm GT. *24 hrs prior to install new GT call the Utility Office to schedule an inspection. *Installation must be inspected and approved by the Newburgh staff to achieve compliance.  2-22-16 50 GPM Grease Trap Installed and Inspected. Looks Good In Compliance
Arbys Permit No. 082813	06/26/13	07/26/13	08/21/13	08/20/13	Passed by Council on 9/11/13	8/23/13: Passed	In Compliance

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Archie & Clyde's Permit No. 042613	03/11/13	04/11/13	04/19/13	04/23/13	Passed by Council on 5/8/13	04/19/13: Passed	In Compliance
Azzip Pizza Permit No. 112414				09/26/14	Passed by Council 12-10-14		Change of use. The in-floor grease trap must be replaced with a larger 50 gpm grease trap by June 10, 2015. <u>6/26/15 No Response</u>  Letter Sent 8/11/15 9/10/15 Talked To George Hoffman About Changing To A 50 GPM Trap. He Asked how Much Time he has and we give Him 30 Days. Deadline Date Is 10/10/15.  10-6-15: Spoke to Dan Niemier by phone. Dan will submit a compliance schedule with a time line to Kristen. Dan will submit FOG equipment detail sheets and vendor literature for approval prior to installation. LK  10-19-15 50 GPM Installed and Inspected. OK In Compliance
Beef-O-Bradys Permit No. 121313	11/25/13	12/25/13	12/13/13	12/05/13	Passed by Council on 01/8/14	12/16/13: Passed	In Compliance
Bell Oaks Terrace Permit No. 022513	1/23/2013  10-12-16	2/22/2013  11-1-16	02/06/13 03/06/13  11-4-16	02/14/13	Passed by Council on 03/13/13	3/7/13: Passed  11-21-16	In Compliance  NOV sent 10-12-16. Must comply by 11-1-16. In compliance

# Newburgh Wastewater Treatment Facilities FOG NOV Status Report

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Bordy's Pizza	8/8/2014  2-4-15 4-22-15  05/07/2015 Hand-Delivered 7/31/15	9/8/2014  2-24-15 5-22-15  05/27/2015					<p>New FSE. Notice sent 8-8-14 informing FSE of the need to obtain a FOG discharge permit. Submittals are due by 9-8-14.</p> <p>No Response. New notice sent 2-4-15 giving 20 days to comply. Was returned undeliverable</p> <p>Another notice sent 4-22-15. Per 4-28-15 internal mtg: If no response, Susan will send 1st NOV after 5-22-15.</p> <p>Talked with Anthony on 5-29-15 and he said would get questionnaire into us this week 6-3-15.</p> <p>6-8-15: Did not receive questionnaire. Chris to send NOV with fine. 6/26/15 No Response <u>Chris Will Send Letter With Fines</u> A new business has opened in this building: Little Angelo's</p>
Boston Pizza Draft Permit No. 022714	1/23/13 3/13/13	2/22/13 04/2/13	No 5/16/13	4/22/13, Questionnaire is incomplete	Permit Issued 3/13/14	5/16/13: Passed	In Compliance
Brentwood Meadows Permit No. 021913	1/23/2013  12-5-16	  12-25-16	2/8/13 3/13/13  12-9-16	02/01/13	Passed by Council on 03/13/13	2/11/13: Failed 3/14/13 10-13-15 Failed 12-9-16	In Compliance  Passed NOV sent 12-5-16  Passed In compliance
Burger King Permit No. 123113	11/25/13	12/25/13	12/13/13	12/16/13	Passed by Council on 01/08/14	12/23/13: Passed	In Compliance
Burger King Bellmoore Drive Permit No.092016				09/02/16	To UC on 10-5-16	10/12/16	<p>New Facility.</p> <p>11-18-16 New 1500 Gallon Interceptor Installed and inspected. Cleanout castings in concrete still need to be installed.</p>

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Café Arazu Permit No.012815	11/25/2013  12-5-16 on 35 GPM Trap IN liquor room	12/25/2013  12-25-16		01/03/14	To Council on 2-11-15		<p>Waiver requested to allow internal grease trap(s). Calculations indicate a need for additional grease traps. UC has given Café Arazu 30 days to submit a corrective action plan for review. The plan is due on March 7, 2014. 3-5-14: Café Arazu responded with a plan. The plan is deficient. We need additional information.</p> <p>June 2014: Ed met with Cafe Arazu's plumber and traced all plumbing fixtures in the building to generate a drawing of the drainage plumbing tree. The drawing indicates that the bar drainage fixtures need to be separated from the kitchen fixtures. Once separated the kitchen will need to have another grease trap installed. The existing 25 gpm grease trap services the dishwasher. We need to know the gpm rating of the dishwasher to determine if the grease trap is big enough.</p> <p>8-5-14: Chris sent a letter outlining tasks to be completed to obtain compliance. The FSE instructed to respond with a compliance time line. 12/29/14: New 35 GPM Grease Trap was installed and inspected. Everything is in order.</p> <p>In compliance NOV sent 12-5-16 In Compliance</p> <p>10-19-16 Failed 12-22-16 Passed</p>
Casey's General Store Permit No. 091013	06/26/13	07/26/13	9/11/13 9/26/13	09/04/13	10/9/2013	9/11/13 9/26/13	In compliance Passed

# Newburgh Wastewater Treatment Facilities FOG NOV Status Report

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Castle High School	04/12/13	05/12/13				11/25/14: Failed	<p>Mark Neff replied with letter on 6/26/13 with questions on our policy. Chris will respond. Referred to Legal.</p> <p>11-25-14: FOG interceptor was reinspected. The interceptor failed inspection. The interceptor was 78% full of FOG and sludge. Referred to legal.</p> <p>Per 4-28-15 internal mtg: Chris will respond</p> <p>6-5-15: Inspection revealed the interceptor is 100% full of FOG. Notified Chris of findings. Chris will contact Mark Neff.</p> <p>6/5/15 9:48 AM Found Grease Interceptor 100% Full 8/11/15 Had been cleaned but not notified</p> <p>10-23-15: received questionnaire. Meeting with Mark Neff and School Corp staff has been set for 11-13-15. Meeting was cancelled due to schedule conflict by M. Neff....To be rescheduled.</p> <p>7-6-16: Chris &amp; Leon met with Mark Neff, John Stucker, &amp; Shenae Rowe concerning the FOG violation. School Corp staff described best management practices for FOG mitigation and informed us that they had changed cleaning contractors. Leon suggested that if the school corp. would install a sample access point, the Town would sample and test the existing interceptor discharge to determine if the BMP mitigation is enough to gain compliance.</p> <p>7-14-16: Sean Sanders met with school corporation staff. School corp. modified the grease interceptor outlet so that we could obtain discharge samples. Newburgh will test the discharge to determine compliance.</p> <p>9-21-16 Pulled FOG sample for testing. FOG Test result was 147mg/l. This is a violation of the FOG Ordinance. Referred to Chris on 10-5-16.</p>

# Newburgh Wastewater Treatment Facilities FOG NOV Status Report

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Castle North Middle School	06/24/13	07/24/13	07/11/13	No response		7/12/13 OK	<p>Questionnaire has not been submitted. Without the questionnaire we cannot determine if the interceptor is sized appropriately. Enforcement action is necessary. Referred to Legal.</p> <p>Per 4-28-15 internal mtg: Chris will respond.</p> <p>6-5-15 Inspection revealed the interceptor is 51% Full.</p> <p>10-23-15: received questionnaire. Meeting with Mark Neff and School Corp staff has been set for 11-13-15. Meeting was cancelled due to schedule conflict by M. Neff....To be rescheduled.</p> <p>7-6-16: Chris &amp; Leon met with Mark Neff, John Stucker, &amp; Shenae Rowe concerning the FOG violation. School Corp staff described best management practices for FOG mitigation and informed us that they had changed cleaning contractors. Leon suggested that if the school corp. would install a sample access point, the Town would sample and test the existing interceptor discharge to determine if the BMP mitigation is enough to gain compliance.</p> <p>7-14-16: Sean Sanders met with school corporation staff.School corp. was to modify the grease interceptor outlet so that we can obtain discharge samples. School corp staff after investigation indicated that it would be too expensive to modify the outlet. Consquently no modification was made to accomodate sampling.</p> <p>8-3-16: UC instructed Chris to send a letter indicating that the school corp must install an approved sampling point on the discharge outlet of the interceptor and that failure to provide the sampling point will result in enforcement action.</p>
China Village Permit No. 061013	12/14/12 03/11/13	1/13/13 03/07/13	N/A	03/22/13	Passed by Council on 7-10-13	N/A	Installed new FOG interceptor on 08/05/13. In Compliance.
Cypress Grove Rehab Permit No. 042313	3/11/13 7/14/14 7/1/15 10-12-16	4/11/13 7/21/15 11-1-16	3/6/13 7-25-14	04/02/13	Passed By Council on 5/8/13	3/7/13: Passed 7/30/14 7-15-15	<p>In Compliance</p> <p>Inspected and Found 5" FOG &amp; 36" Sludge. Baffle Broken. Needs to be repaired. Baffle repaired. Back in compliance.</p> <p>In Compliance</p> <p>NOV sent 10-12-16. Must be in compliance by 11-1-16.</p>

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Dairy Queen Permit No. 121213	7/01/15	12/25/13 7/21/15	12/27/13 6/29/15	12/05/13	Passed by Council on 1/8/14	12/27/13 7/09/15	In Compliance  In Compliance Passed
Deaconess Gateway Hospital Permit No. 031813	1/23/13 06/24/13	2/22/13 07/24/13	02/04/13	03/05/13	Passed by Council on 4/10/13	2/11/13: Passed	In Compliance
Express Pantry Permit No. 091213	08/07/13	09/07/13	N/A	09/04/13	10/9/2013	N/A	Must install internal grease trap. 30 gal. minimum is required. They have until 4/9/14 to install. <del>July, 2014: confirmed that the business is now closed.</del> Reopened....The kitchen has no food prep.... This was confirmed by Ed. No permit is required.
Fat Boy's Pizza Permit No. 052516	08/25/16				Approved by Council 6-8-16		New Facility in operation without grease trap inspection. NOV sent 8-25-16  9-8-16 New 50 GPM Grease Trap Installed and Inspected. In Compliance
Golden Buddha Permit No. 022013	12/14/12  05/07/15		N/A	02/08/13	Passed by Council on 03/13/13	N/A	Permit was approved by Council on 3/13/13. Had a 6 month construction compliance schedule (9/13/13). Referred to legal.  Per 4-28-15 internal mtg: Susan will send 1st NOV.  5-7-15 1st NOV sent. No response. 6-1-15 Chris Sending second NOV With Fees.  6-10-15: Received a letter from GB's attorney. Chris responded via email...requested dates and times to meet and discuss compliance.  10-29-15: To date there has been no response to Chris's email.

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Golden Living Woodlands Permit No. 081813	6/26/13       05/07/15	7/26/13       05/27/15	08/13/13	07/16/13	Passed by Council on 9/11/13	8/13/13: Passed, Baffles were also repaired and passed.	<p>Interceptor size must be increased. There is a 6 month compliance schedule in the permit. Interceptor size to be increased by 3/11/14.</p> <p>Deadline for installation of a new interceptor has passed. Referred to legal .</p> <p>Per 4-28-15 internal mtg: Susan will send 1st NOV.</p> <p>5-15-15 Talked to Benny Frey New administrator Just started. Told him what he needed to do to be in compliance. 5-22-15 the plumber with Woodlands called and said they were getting everything together to submit and installing new 1500 Gallon interceptor. EH</p> <p>Still In Process Of Getting New Grease Interceptor installed</p> <p>Kristen sent NOV on 10-5-15.</p> <p>10-9-15: Spoke to Maribeth, executive director, she was to send in a compliance plan and her contractor was to contact Ed. Ed spoke to contractor. The contractor was to submit compliance plan, spec sheets, and site plan.</p> <p>We are still waiting for the information.</p> <p>Submittals Recieved and Approved on 11-24-15 Scheduled to be installed on 12-3/4/15</p> <p>12-10-15 New 1500 Gallon Grease Interceptor Installed and Inpected. Looks Good</p> <p>In Compliance</p>



**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Hardees Permit No. 013113	1/23/2013  10-12-16	2/22/2013  11-1-16	1/31/13 3/12/13	01/28/13	Passed by Council on 02/13/13	2/11/13: Failed 3/14/13: Passed 12-17-14: Failed  10-24-16	In Compliance Nov Sent 1-9-15: Given 20 days to comply.  3-17-15: Repaired Baffles Looked Good. In Compliance. NOV sent on 10-12-16. Must be in compliance by 11-1-16 Effluent Baffle Re-Installed In Compliance. 10-24-16
Hucks Permit No. 031713	1/23/2013 7/01/15	2/22/13 7/21/15	7/23/15	03/04/13	Passed by Council on 4/10/13	3/1/2013: Passed 7-15-15 7/23/15	In Compliance Failed: 100% Full with 6" of rock In bottom In Compliance
Jaliscos Permit No. 081913	6/26/2013 7/01/15	7/26/2013 7/21/15		07/12/13	Passed by Council on 9/11/13	6/6/14 Passed 7-14-15 Passed	In Compliance In Compliance
Kanpai	N/A			04/15/15			Proposed New FSE. Requesting a wavier of FOG interceptor requirement in favor of FOG traps. Waiver request will go to UC & Council in May, 2015. 5-28-15: Jason Munoz said he was not opening the business.
Knob Hill Tavern Permit No. 092016	08/25/16	09/25/16		09/07/16	To UC on 10-5-16		Noncompliance due to excessive grease discharge in main. Questionnaire due by 9-25-16

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
LaVaranda Permit No. 091113	06/26/13	07/26/13	07/09/13	09/09/13	10/9/2013	7/11/13: Passed	<p>Interceptor size must be increased to 1200 gal Business under option to be bought. Still have a 4-16-14 compliance date. Compliance enforcement is on hold. Permit may need to be revised. La Veranda is currently in discussion with the UC to determine how to obtain compliance.</p> <p>June 2014: Staff determined that the grease interceptor volume 104.7 gallons. The only way the existing grease interceptor will work is if the following conditions are met:            1. The dishwasher must be removed.            2. The kitchen must operate as a single service kitchen.            3. The seating capacity must be limited to 43.            4. The Town Council grants a waiver to the minimum grease interceptor size.</p> <p>8-5-14: Chris sent a letter outlining options to obtain compliance. The FSE instructed to respond with a compliance plan.</p> <p>1-5-15 Inspected kitchen area. The dishwasher has been taken out and a 3 compartment sink put in its place. Still need paperwork on seating capacity and to be run as a single service Kitchen with waiver.</p> <p>In compliance</p>
Little Angelo's Permit No.102615	12-5-16 on 50 GPM Trap	12-25-16		10/26/15	Permit No. 102615 Approved by Council on 11-10-15	10-19-16 Fail 12-22-16 Passed	<p>New Restaurant in an existing building. Permit has been drafted. Permit will go to UC on 11-4-15 for recommendation to Council. Grease Traps Installed &amp; Inspected on 11-19-15 In Compliance</p> <p>NOV sent 12-5-16</p> <p>In Compliance</p>

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Little Caesars Pizza Permit No. 022814	11/25/13  7/01/15 12-5-16	12/25/13  7/21/15 12-25-16	11/18/13 11/25/13  6-24-15	01/13/14	Permit Issued On 3/13/14	11/20/13: Failed 12/03/13: Clean at the time of inspection.  4-16-14: Failed  6-22-15: Failed  7-20-15 Passed 10-9-16 Failed	Wavier request relieving requirement to install an external grease interceptor. Waiver request to allow a 60 gpm grease trap. 3/13/14: Council approved permit.  Must install 60 gpm grease trap by 9-9-14. 3-28-14: Received letter challenging cleaning frequency in the permit.  4-16-14: Newburgh ordered FSE to clean the grease trap immediately.  4-21-14: FSE cleaning frequency was 1 month. FSE was ordered to increase cleaning frequency to every 2 weeks. Must demonstrate that 2 weeks is a sufficient cleaning cycle, otherwise must revert to a 1 week cleaning cycle.  8-27-14: installed new 60 gpm grease trap In compliance  Responded to NOV on 7-15-15. Grease trap was cleaned 2 days after inspection.  In Compliance
Marco's Pizza Permit No. 082913	N. A.	N. A.	N. A.		Passed by Council on 09/11/13	11-14-13 Passed	In Compliance

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
McDonalds Permit No. 032713	1/23/13 03/13/13 10/16/13	2/22/13 04/02/13 11/05/13	3/21/13 10/04/13	03/21/13	Passed by Council on 4/10/13	4/5/13 10/04/13 2/27/14 1-29-15	In Compliance  Failed, numerous grease balls on walls.  Failed, numerous grease balls on walls.  Interceptor seems to be allowing grease pass through. Schedule Sampling and testing interceptor discharge for FOG.  Sample collected and tested for FOG. Lab result was 184 mg/l  2-20-15 NOV sent for discharge exceeding 100 mg/l FOG. Must respond with corrections by 3-12-15.  3/17/15 thru 3/20/15 Called David White 5 different Times and left Messages 5 times.  6-3-15: Re-Sampled. Result was only 70 mg/l. In compliance.
Meijer							Proposed new store. 3-16-15: Sent a notice of FOG pretreatment requirements.
Nellie's ( Letter sent as Five Blessings ) Permit No. 010517	12/16/16	01/16/17		12/21/16			Permit written. Presented to UC on 01-11-17
Newburgh Elementary Permit No. 022813	01/23/13	02/22/13	2/1/13 3/12/13	02/22/13	Passed by Council on 03/13/13	2/8/13: Failed 3/12/13: Passed	In Compliance
Newburgh Health Care Permit No. 022613	1/23/2013  10-12-16	2/22/2013  11-1-16	02/05/13	02/08/13	Passed by Council on 03/13/13	2/8/13: Passed	In Compliance  NOV sent on 10-12-16. Must be in compliance by 11-1-16.

## Newburgh Wastewater Treatment Facilities FOG NOV Status Report

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Ninki Japanese Bistro Permit No. 123115	8-25-16 10-7-16	10-27-16			Passed by Council on 1-13-16	12-14-16	<p>Has a 6 month compliance period.</p> <p>Nov sent on 8-25-16 due to non compliance with the compliance schedule.</p> <p>10-7-16: Susan sent the second NOV. Given 20 days to comply. Two 35 GPM Grease Traps are installed and inspected. Note: Mop sink was barricaded off with screwed down cover and sealed to not be used. Back in compliance</p>
NW Chophouse & Wine Bar Permit No. 123015	7/12/13 2-4-15  10-7-16	8/11/13 2-24-15  10-27-16	N.A.	No response	Permit No. 123015 Passed by Council on 1-13-16		<p>Notice sent on 7-12-13.</p> <p>1st NOV sent 2-4-15 giving 20 days to comply.</p> <p>Per 5-1-15 email: Chris will send 2nd NOV</p> <p>5-12-15 Received partial information, 5-15-15 called Nick and left message that we still needed questionnaire filled out and turned in. Called again on 5-26-15 talked to Nick and told me that he would turn in questionnaire on 5-27-15. As of 6-1-15 have not seen questionnaire.</p> <p>6-9-15: Chris to send an NOV with fine. 6/26/15 Still no questionnaire</p> <p>9-21-15: NOV sent by Kristen.</p> <p>Questionnaire Recieved 11/24-15 Go to UC ON 12-2-15</p> <p>Has a 6 month compliance period, by June 14, 2016. There has been no response.</p> <p>10-7-16: Susan sent the first NOV. Given 20 days to comply.</p>

# Newburgh Wastewater Treatment Facilities FOG NOV Status Report

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Penn Station Permit No. 0100412	11/26/13 2-4-15	12/16/13 2-24-15		No Response	Issued 10-10-12	10/13/13: Failed 12/18/14 Failed 50% Full  9/28/15	NOV sent due to improper maintenance of their internal grease trap. First NOV sent 2-4-15 giving 20 days to comply.  Per 4-28-15 internal mtg: Chris will send 2nd NOV 6-1-15: Have not heard anything. EH  6/26/15: Still not heard anything. EH  9/01/15 Have not heard anything. EH  In Compliance Trap Cleaning Schedule: Daily  Passed inspection.
Pizza Chef Permit No.082515	07/01/15	07/31/15	07/05/15	07/10/15	Approved by Council on 9-9-15	07/07/15 Passed .25 % Full	9-9-15: Council granted 2 waivers: waved interceptor requirement. Waved separate grease trap to service the dishwasher. Required the existing 15 gpm grease trap to be replaced with a 50 gpm grease trap. Have until 3/8/16 To install new 50 GPM Grease Trap 5-11-16 New 50 GPM grease trap installed and inspected and all kitchen plumbing connected to new trap. In Compliance
Pizza Hut Permit No. 022216	12-5-16	12-25-16			Approved by Council on 3-9-16	10-11-16 Fail	The installation of an external in-ground grease interceptor was waived. In lieu of an external in-ground grease interceptor, the existing 75 gpm internal grease trap must be operated and maintained in compliance with the Newburgh FOG ordinance at all times. The installation of a separate grease trap to service the dishwasher was hereby waived. All kitchen plumbing fixtures, including the 2 hand-sinks, must be connected to the 75 gpm grease trap. The plumbing modifications described above must be completed, inspected and approved by the Newburgh Wastewater Treatment Utility (Utility) within 180 days. 75 GPM Graese Trap Installed and Inspected In Compliance NOV sent 12-5-16

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

<b>Business</b>	<b>NOV Sent</b>	<b>NOV Response Due By</b>	<b>Interceptor Cleaned</b>	<b>Questionnaire Received</b>	<b>FOG Discharge Permit</b>	<b>Re-inspection</b>	<b>Status</b>
Priceless Foods Permit No. 092513	6/24/2013	07/24/13	09/17/13	09/19/13	Passed by Council on 10/09/13	7/11/13: Passed	In Compliance  7/14/14: Found old lid leaking ground water. To be repaired by January 2015.  1-29-15: Installing new 1,500 gallon interceptor. 2-6-15: Interceptor Installed and HS-20 Concrete poured with #4 Rebar. Construction complete. In Compliance. Cosed Spring Of 2016 Church is now in this Building
Primrose Retirement Communities Permit No. 122915					Permit No. 122915 Approved by Council 1-13-16		Interceptos must be installed & inspected prior to any discharge.  8-15-16 Main Building 2 each 1500 gallon Graese Interceptors Installed and Inspected  9-26-16 Memory Care 1 Each 1500 Gallon Grease Interceptor Installed and Inspected
Riviera Grill Permit No. 021813	1/23/2013  7/01/15	02/22/13  7/21/15	Don't Know  6/29/15	02/11/13	Passed by Council on 03/13/13	4/5/13  7/08/15	In Compliance  In Compliance

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

<b>Business</b>	<b>NOV Sent</b>	<b>NOV Response Due By</b>	<b>Interceptor Cleaned</b>	<b>Questionnaire Received</b>	<b>FOG Discharge Permit</b>	<b>Re-inspection</b>	<b>Status</b>
Rose Hill Café Permit No. 062315	1/6/15  05/07/15	2/6/15  05/27/15		5/22/15	Passed by Council on 7-8-15	12-18-14: Failed  5-26-15 Passed	<p>Must apply for a FOG Permit. No response to Notice letter.</p> <p>Per 4-28-15 internal mtg: Susan will send 1st NOV.</p> <p>Is going to ask for waiver for grease interceptor, I told him that we needed a letter asking for the waiver and the reason for waiver and also needed the GPM rating on the dishwasher so we can figure his capacity.</p> <p>6-10-15: interceptor waiver granted. Permit was approved by Council on 7-8-15.</p> <p>There is a 180 day compliance schedule in the permit. Compliance is required by January 7, 2016.</p> <p>1-22-16 EH Spoke with owner Mark Schmidt and told him that he needs to turn in shop drawings or 40 GPM GT, and that he needs to give us a compliance plan within 20 days. Also that all fixtures need to be plumbed into this new 40 GPM GT.</p> <p>Cut Sheet on a 50 GPM grease trap recieved on 1/28/16 and Approved. Mike Bayer said they did not make a 40 GPM, so he upsized to a 50 GPM Trap. Also said he was planning on installing this trap on Monday 2/1/16.</p> <p>2/1/16 Grease trap Installed and Inspected. OK</p> <p>In Compliance</p>
Sakura							Letter sent to new restaurant on 12-16-16. Submittals required to be submitted by 1-16-17.
Schnucks Permit No. 022713	01/23/13	02/22/13	03/27/13	02/08/13	Passed by Council on 03/13/13	3/28/13: Passed	In Compliance



**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Sharon Elementary School							<p>8-3-16: Informed the UC that we have been unable to locate the grease interceptor for the Sharon Elementary School and suggested that a letter be sent instructing the school corp to locate the FOG interceptor and to provide a sampling point.</p> <p>8-3-16: UC instructed Chris to send a letter indicating that the school corp must locate &amp; install an approved sampling point on the discharge outlet of the interceptor and that failure to provide the sampling point will result in enforcement action.</p>
Spuds & Stuff Permit No. 101615	1/6/15  05/07/15	2/6/14  05/27/15		6-8-15	Permit No. 101615 Approved by Council on 11-10-15		<p>New Facility. Must apply for FOG Discharge Permit. No response to NOV letter.</p> <p>Per 4-28-15 internal mtg: Susan will send 1st NOV. 5-11-15 Talked to Manager and told her that she needed to turn in the questionnaire. No reply. Chris is sending 2nd NOV with Fees. Received questionnaire waiting for letter asking for variance.</p> <p>Have not heard anything 9/23/15 Received Letter asking for variance. Going To UC on 10/7/15</p> <p>Received waiver request on 9-24-15. Permit has been drafted and will go to UC on 11-4-15. Permit Approved 11-10-15 by Council In Compliance</p>
Taco Bell Permit No. 072913	06/26/13	07/26/13	07/02/13	07/01/13	Passed by Council on 8-14-13	7/3/13: Passed	In Compliance
Tin Fish	12/05/16	01/05/17		12/22/16			<p>Inspected on 10-19-16 &amp; failed the inspection. NOV sent 12-5-16. The iterceptor needs to be cleaned and the questionnaire needs to be submitted. Must obtain a FOG discharge pretreatment permit. On 12-20-16 requested FOG Policy wavier. Presented wavier to UC on 1-11-17.</p>

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Towne Market Permit No. 042716					Approved by Council on 5-11-16		<p>The installation of an external in-ground grease interceptor was waived in accordance with Ordinance 2012-20, Section 1(V)(1).</p> <p>Section 3(A)(X) of Newburgh Ordinance 2012-20 was also waived to allow more than four kitchen fixtures to discharge to a single grease trap.</p> <p>The installation of a 50 gpm (100 lb.) internal in-floor grease trap which services all kitchen fixtures is required.</p> <p>The grease trap described in Sections (B) above, must be installed, inspected and approved by the Newburgh Wastewater Treatment Utility (Utility) before commencing any wastewater discharges to the sanitary sewer system.</p> <p>New 50 GPM Grease Trap Installed and Inspected on 6-2-16. In Compliance</p>
Turoni's Pizza Permit No. 032613	01/23/13 03/13/13	02/22/13 04/02/13	04/24/13	03/21/13	Passed by Council on 4/10/13	05/06/13: Passed	In Compliance
Vecchio's Italian Market	2/2/15  05/07/15	05/27/15					<p>Required to respond within 30 days. Never opened for business.</p> <p>Per 4-28-15 internal mtg: Susan will send a new notice.</p> <p>6-9-15: Chris to send NOV with fine. 6/26/15: No response 9-21-15: Kristen sent NOV</p> <p>By Our Understanding the Buisness Is Closed as per Chris Wischer &amp; Christy's E-mail String</p>

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Victoria Nat. Golf Club Permit No. 112713	10/8/2013  12-5-16	11/8/2013  12-25-16	10/2/2013 1/3/2014  11-17-16	10/16/13	to UC on 12-4-13	10/2/13: Passed 1/3/14 Passed 10-13-16 Failed 12-20-16	In Compliance  NOV sent 10-5-16  Passed. Met with Steve Munch and he informed me that they were going to start cleaning their interceptor every 60 days during their busy season. I told him that this sounds great but we would still keep a wach on their interceptor. In Compliance
Walmart (Bell Moore) Permit No. 052813	03/21/13	04/20/13	04/05/13	05/09/13	Passed by Council on 6/12/13.	4/09/13: Passed	In Compliance
Walmart Grocery (Newburgh)							Proposed new store. Per 4-28-15 internal mtg: Susan will send a notice of FOG pretreatment requirements.  Cancelled construction

**Newburgh Wastewater Treatment Facilities  
FOG NOV Status Report**

Updated: January 11, 2017

Business	NOV Sent	NOV Response Due By	Interceptor Cleaned	Questionnaire Received	FOG Discharge Permit	Re-inspection	Status
Wendy's Permit No. 032513	2/28/13	3/28/13	03/12/13	3/20/13	Passed by Council on 4/10/13	3-12-13: Passed	<p>In Compliance</p> <p>8-6-14: A FOG sample was collected from the discharge tee of the FSE's grease interceptor and tested by an independent laboratory. The test result quantified the oil and grease discharge at 934 mg/l. This exceeds the maximum FOG discharge allowed by ordinance and permit (i.e. 100mg/l). Recommend that an NOV be sent.</p> <p>Problem corrected by Wendy's contractor. Newburgh staff will schedule another round of sampling and testing. Re-sampled on 6/3/15. Sample came back with a reading of 159 mg/l. I think Susan wrote them a letter</p> <p>Will Resample In about 3 Weeks. Re-sampled On 9/3/15 Results came back with a reading of 119 mg/L. Susan sent letter on 9/23/15. Has 20 Days to respond.</p> <p>Ed has spoken to Wendy's. They are planning to replace the existing interceptor with a larger one in the spring. In the meantime, they will increase their cleaning frequency. They are to submit a compliance plan by 10-30-15.</p> <p>Compliance Plan Approved on 11-4-15 New 1500 Gallon Interceptor Installed by 6-1-16, In the meantime they clean existing Interceptor every 60 Days.</p> <p>7-13-16 New 1500 Gallon Grease Interceptor Installed and Inspected</p> <p>In Compliance</p>